

Summary Report for Lead in Water Sampling at the Universal Vare Charter School 1901 S. 23rd Street, Philadelphia, Pa



Prepared for
Lawrence Threadgill
Universal Companies
1427 Catharine Street, 4th Floor
Philadelphia, Pennsylvania 19146

Prepared by
FIG Environmental LLC
PO Box 8574, Turnersville, NJ 08012
EPA Lead Safe Certified Firm #NAT-F273209-1
PA Lead Risk Assessor #004799

FIG Project ID: C-25-062
August 2025

Introduction

On August 7, 2025, water sampling was performed as part of an ongoing lead-in-drinking-water monitoring program designed to assess, document, and verify compliance with acceptable water quality standards at all accessible potable water outlets within the K–8 charter school facility. The scope of work included the collection and laboratory analysis of water samples for lead concentration.

This report provides a detailed summary of the sampling methodology and sampling results.

Understanding Lead in Drinking Water

Lead is a metal that can be found in natural deposits, but most lead in drinking water comes from plumbing materials — like pipes, faucets, and fixtures — rather than from the water source itself. It can get into drinking water when these materials corrode, especially in older homes or buildings.

Buildings built before 1986 are more likely to have pipes, solder, or fixtures made with lead. But even newer buildings aren't completely safe — plumbing labeled “lead-free” could still have small amounts of lead. Brass faucets or chrome-plated fixtures are common sources, especially when hot water is used.

When lead is found in drinking water, the resolution may involve replacing parts of the plumbing system with lead-free materials.

There is no safe level of lead exposure. Even small amounts can affect your health. Lead is a toxic metal that adversely affects the nervous system in both children and adults. Prolonged exposure may impair cognitive function and other neurological processes. In adults, particularly those who are middle-aged or older, lead exposure has also been associated with elevated blood pressure and may lead to anemia.

At high levels, lead can cause severe damage to the brain and kidneys in both adults and children, and in extreme cases, may be fatal.

Lead is undetectable by taste, or smell, making it difficult to identify in drinking water without proper testing. The health effects of low-level exposure are often not immediately apparent. Symptoms, if present, may be subtle or mistaken for other illnesses, such as the flu.

Many water treatment systems are capable of significantly reducing lead levels in drinking water, though their effectiveness varies by system type and maintenance.

National Primary Drinking Water Regulations

The National Primary Drinking Water Regulations (NPDWRs) are legally enforceable standards issued by the U.S. Environmental Protection Agency (EPA) to protect public health by limiting contaminants in public drinking water systems. The purpose of the NPDWRs is to ensure safe drinking water by setting limits on contaminants that can adversely affect human health. Maximum Contaminant Levels (MCLs) are the highest amount of a contaminant allowed in drinking water delivered by public water systems, as set by the EPA under the National NPDWRs.

In accordance with the City of Philadelphia Code, the Action Level (AL) for lead (Pb) in drinking water is 10 micrograms per liter (µg/L), or 10 parts per billion (ppb). By comparison, the Environmental Protection Agency (EPA) sets the federal drinking water standard at 15 micrograms per liter (µg/L). The Action Level represents the concentration of lead in water at which certain regulatory responses may be required, including corrosion control treatment, source water treatment, lead service line replacement, and public education.

Codes & Standards

There are currently no state or federal regulations that mandate the testing of drinking water in schools, with the exception of institutions that operate their own water supply systems and are therefore governed by the Safe Drinking Water Act (SDWA). The vast majority of public water suppliers do not incorporate schools into their routine sampling protocols, as existing regulations—specifically the Lead and Copper Rule—primarily require sampling from single-family residential dwellings. Nevertheless, Section A-703.2; B. of The Philadelphia Code establishes that *“The Health Department or a testing agency certified by the Pennsylvania Department of Environmental Protection has certified, within the previous five years, that the building is in substantial compliance with applicable water quality requirements of the Board of Health, provided that in no event shall applicable water quality requirements be deemed to permit lead in water at an outlet such as a sink or water fountain that is in service at 10 ppb or more. Any water outlet determined to exceed any such water quality requirements shall be taken out of service within 24 hours of notification of the relevant test. The owner of the educational occupancy shall post the results of the most recent water quality testing at each educational occupancy to a generally available website within ten days of receipt of the results.”*

Board of Health Requirements for Water Outlet Testing and Reporting

In accordance with Board of Health regulations, your facility is responsible for reporting the testing of all potable water outlets. Test results must be submitted to the Philadelphia Department of Public Health via email at **WfilterLeadTest11g@phila.gov**.

Each submission must include the following:

1. Cover Letter

- Include the name, address, and contact information of your facility.
- Clearly identify the purpose of the submission.

2. Laboratory Report

- Provide the sampling date.
- Identify the laboratory that conducted the analysis.
- Report the lead concentration for each potable water outlet tested.

3. Response to Elevated Lead Levels

- If any outlet shows a lead concentration **equal to or exceeding 10 parts per billion (µg/L)**, you are required to discontinue use of that outlet **within 24 hours**.
- Describe the corrective action(s) taken in response to elevated levels in the cover letter.
- An outlet may only be returned to service **after corrective measures have been implemented**, and a follow-up test confirms that the lead level is **below 10 parts per billion (µg/L)**.

Please ensure all documentation is complete and submitted promptly to ensure compliance with health and safety regulations.

Sampling Compliance

All water samples were collected by a licensed Pennsylvania Lead Risk Assessor in the recommended pre-cleaned, 250 mL sampling container supplied by the laboratory, EMSL Analytical of Cinnaminson, New Jersey (NLLAP accredited laboratory). Sampling included both a “first draw” and a “flush” sample taken from each drinking water outlet, as well as a first draw sample from filtered bottle filler outlets. In accordance with EPA 40 CFR Part 141 Subpart I (Lead and Copper Rule) guidelines, all outlets were ideally left unused for a minimum of 6 hours prior to sample collection. The samples were analyzed via Metals ICP-MS-EPA 200.8

Sampling Results

Table No. 1 outlines the sampling data and analytical results from water samples collected on August 07, 2025 at the Universal Vare Charter School:

Table No. 1				
Sample #	Outlet Source	Draw Sample	Location	Results
1	S	First	Room 307 Sink	113 AAL
2	S	Flush		4.78
3	S	First	Room 308 Sink	7.03
4	S	Flush		1.18
5	F	First	Hall Fountain outside Room 308	ND
6	F	Flush		ND
7	BF	First	Bottle Filler outside Room 308	ND
8	F	First	3 rd Floor Hall Fountain (Low)	ND
9	F	Flush		ND

10	F	First	3 rd Floor Hall Fountain (High)	ND
11	F	Flush		ND
12	S	First	Room 309 Sink	2.19
13	S	Flush		ND
14	S	First	Room 310 Sink	11.0 AAL
15	S	Flush		1.02
16	S	First	Room 313 Sink	6.80
17	S	Flush		ND
18	S	First	Room 206 Sink	3.33
19	S	Flush		ND
20	S	First	Room 207 Sink	1.82
21	S	Flush		ND
22	S	First	Room 208 Sink	3.88
23	S	Flush		1.58
24	BF	First	Hall Fountain outside Room 208 (Bottle Filler)	ND
25	BF	Flush		ND
26	S	First	Room 209 Sink (see sample #46 for Flush)	7.66
27	F	First	1 st Floor Hall Fountain	ND
28	F	Flush		ND
29	BF	First	1 st Floor Hall Bottle Filler outside Lobby	ND
30	S	First	K2 Sink	ND
31	S	Flush		ND
32	S	First	K3 Sink	4.87
33	S	Flush		ND
34	S	First	K1 Sink	1.45
35	S	Flush		ND
36	S	First	K4 Sink	2.65
37	S	Flush		ND
38	F	First	Auditorium Fountain (Low) outside Girls Bathroom	ND
39	F	Flush		ND
40	F	First	Auditorium Fountain (High) outside Girls Bathroom	ND
41	F	Flush		ND
42	S	First	Basement Kitchen / Right Sink	1.45
43	S	Flush		ND
44	S	First	Basement Kitchen / Left Sink	4.67
45	S	Flush		ND
46	S	Flush	Room 209 Sink (see sample #26 for First)	1.07
47	S	First	Room 213 Sink	123 AAL
48	S	Flush		2.54
49	S	First	Room 210 Sink	ND
50	S	Flush		1.12
51	S	First	Nurses Office Sink	ND
52	S	Flush		1.55
53	F	First	Hall Fountain outside Library	ND
54	F	Flush		ND

Table No. 2 definitions:

Table No. 2	
F	Fountain
S	Sink
BF	Bottle Filler
AAL	Above Action Level- Remove from Service Immediately
ND	Analyte was NOT DETECTED at or above the detection limit

FIG Environmental LLC is available to address any questions regarding the data provided in this report. Please call our office at 856-553-6162 for further discussions. We appreciate the opportunity given to provide you with our professional services.

John Fiorelli
Project Manager
PA Lead Risk Assessor #004799
FIG Environmental LLC

Attachments (1)

*Summary Report for
Lead in Water Sampling
at the
Universal Vire Charter School
1901 S. 23rd Street, Philadelphia, Pa
August 2025*

ATTACHEMENT NO. 1 LABORATORY RESULTS & CHAIN OF CUSTODY

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03

Project ID: C-25-062-03

Customer PO:

Sales Rep: Justin Monturano

Received: 08/14/2025 11:25

Reported: 08/28/2025 11:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 01/FD - Room 307 Sink Lims Reference ID: AD31842-01 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	113	D	5	5.00	µg/L	08/26/25 12:01	08/27/25 15:01	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: 02/FL - Room 307 Sink Lims Reference ID: AD31842-02 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	4.78		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 03/FD - Room 308 Sink Lims Reference ID: AD31842-03 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	7.03		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 04/FL - Room 308 Sink Lims Reference ID: AD31842-04 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.18		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 05/FD - Fountain O/S 308 Hall Lims Reference ID: AD31842-05 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 06/FL - Fountain O/S 308 Hall Lims Reference ID: AD31842-06 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 07/FD - Bottle Fill O/S 308 Lims Reference ID: AD31842-07 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 08/FD - Hall 3rd Fountain Low Lims Reference ID: AD31842-08 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 09/FL - Hall 3rd Fountain Low Lims Reference ID: AD31842-09 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03**Project ID:** C-25-062-03**Customer PO:****Sales Rep:** Justin Monturano**Received:** 08/14/2025 11:25**Reported:** 08/28/2025 11:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: 09/FL - Hall 3rd Fountain Low (Continued) Lims Reference ID: AD31842-09 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals (Continued)

Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 10/FD - 3rd Hall Fountain High Lims Reference ID: AD31842-10 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:07	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 11/FL - 3rd Hall Fountain High Lims Reference ID: AD31842-11 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:08	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 12/FD - Room 309 Sink Lims Reference ID: AD31842-12 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	2.19		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:10	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 13/FL - Room 309 Sink Lims Reference ID: AD31842-13 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:12	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 14/FD - Room 310 Sink Lims Reference ID: AD31842-14 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	11.0		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 15/FL - Room 310 Sink Lims Reference ID: AD31842-15 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	1.02		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:20	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 16/FD - Room 313 Sink Lims Reference ID: AD31842-16 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

Lead	6.80		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:22	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 17/FL - Room 313 Sink Lims Reference ID: AD31842-17 Matrix: Drinking Water Sampled: 08/07/25 00:00:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03**Project ID:** C-25-062-03**Customer PO:****Sales Rep:** Justin Monturano**Received:** 08/14/2025 11:25**Reported:** 08/28/2025 11:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 17/FL - Room 313 Sink (Continued) Lims Reference ID: AD31842-17 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18/FD - Room 206 Sink Lims Reference ID: AD31842-18 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	3.33		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19/FL - Room 206 Sink Lims Reference ID: AD31842-19 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20/FD - Room 207 Sink Lims Reference ID: AD31842-20 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.82		1	1.00	µg/L	08/22/25 12:44	08/25/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21/FL - Room 207 Sink Lims Reference ID: AD31842-21 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22/FD - Room 208 Sink Lims Reference ID: AD31842-22 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	3.88		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23/FL - Room 208 Sink Lims Reference ID: AD31842-23 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.58		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24/FD - Fountain O/S 208 Hall (Bottle Fill) Lims Reference ID: AD31842-24 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25/FL - Fountain O/S 208 Hall (Bottle Fill) Lims Reference ID: AD31842-25 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03

Project ID: C-25-062-03

Customer PO:

Sales Rep: Justin Monturano

Received: 08/14/2025 11:25

Reported: 08/28/2025 11:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 25/FL - Fountain O/S 208 Hall (Bottle Fill) (Continued) Lims Reference ID: AD31842-25 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26/FD - Room 209 Sink Lims Reference ID: AD31842-26 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	7.66		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27/FD - 1st FI Hall Fountain Lims Reference ID: AD31842-32 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28/FL - 1st FI Hall Fountain Lims Reference ID: AD31842-33 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29/FD - 1st FI Hall Bottle Fill O/S Lobby Lims Reference ID: AD31842-34 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 12:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30/FD - K-2 Sink Lims Reference ID: AD31842-35 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 12:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31/FL - K-2 Sink Lims Reference ID: AD31842-36 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32/FD - K-3 Sink Lims Reference ID: AD31842-37 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	4.87		1	1.00	µg/L	08/22/25 12:38	08/25/25 13:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33/FL - K-3 Sink Lims Reference ID: AD31842-38 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03**Project ID:** C-25-062-03**Customer PO:****Sales Rep:** Justin Monturano**Received:** 08/14/2025 11:25**Reported:** 08/28/2025 11:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 33/FL - K-3 Sink (Continued) Lims Reference ID: AD31842-38 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34/FD - K-1 Sink Lims Reference ID: AD31842-39 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.45		1	1.00	µg/L	08/26/25 12:01	08/27/25 13:46	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: 35/FL - K-1 Sink Lims Reference ID: AD31842-40 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36/FD - K-4 Sink Lims Reference ID: AD31842-41 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	2.65		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 37/FL - K-4 Sink Lims Reference ID: AD31842-42 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38/FD - Aud. Low Fountain O/S Girl's Bath Lims Reference ID: AD31842-43 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39/FL - Aud. Low Fountain O/S Girl's Bath Lims Reference ID: AD31842-44 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40/FD - Aud. High Fountain O/S Girl's Bath Lims Reference ID: AD31842-45 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 41/FL - Aud. High Fountain O/S Girl's Bath Lims Reference ID: AD31842-46 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03**Project ID:** C-25-062-03**Customer PO:****Sales Rep:** Justin Monturano**Received:** 08/14/2025 11:25**Reported:** 08/28/2025 11:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 41/FL - Aud. High Fountain O/S Girl's Bath (Continued) Lims Reference ID: AD31842-46 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 42/FD - Basement Kitchen Sink Right Lims Reference ID: AD31842-47 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.45		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 43/FL - Basement Kitchen Sink Right Lims Reference ID: AD31842-48 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44/FD - Basement Kitchen Sink Left Lims Reference ID: AD31842-49 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	4.67		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 45/FL - Basement Kitchen Sink Left Lims Reference ID: AD31842-50 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 12:38	08/25/25 14:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 46/FL - Rm. 209 Lims Reference ID: AD31842-51 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.07		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47/FD- Room 213 Lims Reference ID: AD31842-52 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	123	D	5	1.00	µg/L	08/25/25 12:30	08/25/25 16:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 48/FL- Room 213 Lims Reference ID: AD31842-53 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	2.54		1	1.00	µg/L	08/26/25 12:01	08/27/25 15:03	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: 49/FD - Room 210 Sink Lims Reference ID: AD31842-54 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03**Project ID:** C-25-062-03**Customer PO:****Sales Rep:** Justin Monturano**Received:** 08/14/2025 11:25**Reported:** 08/28/2025 11:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 49/FD - Room 210 Sink (Continued) Lims Reference ID: AD31842-54 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 50/FL - Room 210 Sink Lims Reference ID: AD31842-55 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.12		1	1.00	µg/L	08/25/25 12:30	08/25/25 16:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 51/FD- Nurse's Office Sink Lims Reference ID: AD31842-56 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 52/FL- Nurse's Office Sink Lims Reference ID: AD31842-57 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	1.55		1	1.00	µg/L	08/25/25 12:30	08/25/25 16:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 53/FD - Hall Fountain o/s Library Lims Reference ID: AD31842-58 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/25 10:43	08/22/25 11:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 54/FL - Hall Fountain o/s Library Lims Reference ID: AD31842-59 Matrix: Drinking Water Sampled: 08/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/25/25 12:30	08/25/25 16:14	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842

LIMS Reference ID: AD31842

EMSL Customer ID: FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03

Project ID: C-25-062-03

Customer PO:

Sales Rep: Justin Monturano

Received: 08/14/2025 11:25

Reported: 08/28/2025 11:49

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531842**LIMS Reference ID:** AD31842**EMSL Customer ID:** FIGE23

Attention: Janae Fiorelli
FIG Environmental LLC [FIGE23]
PO Box 8574
Turnersville, NJ 08012-8574
856-553-6162

Project Name: Universal Vare School / C-25-062-03

Project ID: C-25-062-03

Customer PO:

Sales Rep: Justin Monturano

Received: 08/14/2025 11:25

Reported: 08/28/2025 11:49

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
P3	Sample was preserved by client prior to getting into laboratory.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



AD31842

FIG Environmental LLC
PO BOX 8574
Turnersville, New Jersey 08012-8574
www.figenvironmental.com
contact@figenvironmental.com
856-553-6162

Pb in Water SAMPLE CHAIN OF CUSTODY

PROJECT NAME
PROJECT ID
COLLECTED BY
TRANSMITTED BY

UNIVERSITY OF DELAWARE
C-25-062-03
Sgt. P. P. P.
JDP

DATE
ANALYSIS
TURNAROUND TIME
LABORATORY

08/03/25
JCP. P. P. P.
10 days
EPA

Sample #	Volume	Sample Designation (FD=First Draw, FL=Flush)	Outlet Location	Note
01		FD	Room 307 Sink	
02		FL	Room 308 Sink	
03		FD	Room 308 Sink	
04		FL	Room 308 Sink	
05		FD	Room 308 Sink	
06		FL	Room 308 Sink	
07		FD	Room 308 Sink	
08		FD	Room 308 Sink	
09		FL	Room 308 Sink	
10		FD	Room 308 Sink	
11		FL	Room 308 Sink	
12		FD	Room 308 Sink	
13		FL	Room 308 Sink	
14		FD	Room 308 Sink	
15		FL	Room 308 Sink	
16		FD	Room 308 Sink	
17		FL	Room 308 Sink	



AD 31842

Pb in Water SAMPLE CHAIN OF CUSTODY

FIG Environmental LLC
PO BOX 8574
Turnersville, New Jersey 08012-8574
www.figenvironmental.com
contact@figenvironmental.com
856-553-6162

PROJECT NAME
PROJECT ID
COLLECTED BY
TRANSMITTED BY

University of the Sacred Heart
C-25-062-03
John P. O'Brien
JPO

DATE
ANALYSIS
TURNAROUND TIME
LABORATORY

08/07/25
EPA Method 8210
10 days
EPA

Sample #	Volume	Sample Designation (FD=First Draw, FL=Flush)	Outlet Location	Note
18		FL	Room 206 sink.	
19		FL	↓	
20		FL	Room 207 sink.	
21		FL	↓	
22		FL	Room 208 sink.	
23		FL	↓	
24		FL	Fountain of Room 208 possibly filled.	
25		FL	↓	
26		FL	Room 209 sink.	
27		FL	Hall fountain left	
28		FL	↓	
29		FL	Hall possibly filled. 015 lobby.	
30		FL	K-2 Room sink	
31		FL	↓	
32		FL	K-3 Room sink	
33		FL	↓	
34		FL	K-1 Room sink	



AD 31842

FIG Environmental LLC
PO BOX 8574
Turnersville, New Jersey 08012-8574
www.figenvironmental.com
contact@figenvironmental.com
856-553-6162

Pb in Water SAMPLE CHAIN OF CUSTODY

PROJECT NAME	UNIVERSAL VAPOR School
PROJECT ID	C-25-062003
COLLECTED BY	John J. O'Brien
TRANSMITTED BY	SPR

DATE	08/07/25
ANALYSIS	PCP ms POMMS
TURNAROUND TIME	10 days
LABORATORY	EWCL

Sample #	Volume	Sample Designation (FD=First Draw, FL=Flush)	Outlet Location	Note
35		PL	K-1 Room Sink	
36		FL	K-4 Room Sink	
37		FL	K-4 Room Sink	
38		FD	Auditorium fountain low of S Gilly's Arch	
39		PL	J	
40		FD	Auditorium for Mr. Hilde of S Gilly's Arch	
41		PL	J	
42		FD	K. T. Hilde sink	Remant
43		PL	J	
44		FD	K. T. Hilde sink	
45		PL	J	
46		FL	Room 209 flush	REF TO SINK 20 FD
47		FD	Room 213 sink	
48		PL	J	
49		FD	Room 210 sink	
50		PL	J	
51		FD	Woods's office sink	



Pb in Water SAMPLE CHAIN OF CUSTODY

Page 13 of 13

University of the South
C-25-062-01
John F. Biele
JF

08/10/25
DCC-MS
10 DAY
inst.

[illegible]